9 August 2012

Andy Vernon

Area Sales Manager FP McCann Ltd Whitehill Road Ellistown Leicestershire LE67 1ET



## SCOTTISH WATER

Castle House 6 Castle Drive Carnegie Campus Dunfermline Fife KY11 8GG

Customer Helpline T: 0845 601 8855

W: www.scottishwater.co.uk

E: customer.service@scottishwater.co.uk

Dear Sirs,

## McCann Easi Base - Product Acceptance

Having given due consideration to the use of FP McCann Easi-base pre-constructed bases, and being aware that they have been assessed against the appropriate standards by WRc, I can confirm that Scottish Water has no objections to their use or adoption.

Scottish Water therefore gives full acceptance for the installation of the following products:-

- Easi-Base Pre-cast Concrete Manhole Base with Polypropylene Lining 1200mm diameter, WRc certificate - PT/274/0808 (valid 20/1/2008 to 20/1/2013)
- Easi-Base Pre-cast Manhole Bases with unlined 1200mm, 1500mm, 1800mm and 2100mm diameter, WRc certificate - PT/279/0109 (valid 20/1/2009 to 20/1/2014)
- Easi-Base Pre-cast Manhole Bases with GRP lined 1200mm, 1500mm, 1800mm and 2100mm diameter, WRc certificate PT/280/0109 (valid 20/1/2009 to 20/1/2014)

This acceptance is subject in all regards to conformity with the relevant edition of Sewers for Scotland applying at the time, Scottish Water's Standards and Specifications, Scottish Water's Environmental Policies or any subsequent publication or Regulation that replaces these documents as designated by Scottish Water . This includes the supplementary performance and durability requirements of BS 5911 part 3. For clarity, we regard the current quality of benching in the product is equal or better to that in Sewers for Scotland and therefore deem it to conform.

Acceptance of the current products listed above by Scottish Water is valid with immediate effect. Where WRc certification expires you are required to provide evidence of renewed or extended certification in order to maintain product acceptance. In giving product acceptance Scottish Water reserves the right to review such acceptance at any time if it becomes non-compliant with Sewers for Scotland or any subsequent publication or Regulation that replaces it.

Yours faithfully

Iain MacDonald

Asset Management Technical Leader lain.macdonald@scottishwater.co.uk