

Wessex Water
Claverton Down
BATH
BA2 7WW

Direct dial: 01225-526496
email: john.hayes@wessexwater.co.uk

3 August 2011

A Cooper
F P McCann Ltd
Ellistown Plant
Whitehill Road
Ellistown
Leicestershire LE67 1ET

Dear Sirs,

Wessex Water – Product Approval (Pre-cast wide wall sealed Manhole System)

I am pleased to confirm the F P McCann manhole system incorporating a pre-cast concrete base, wide wall sealed manhole rings is approved for use in the Wessex Water region. This approval is based on the following Concrete Pipelines Systems Association (CPSA) requirements:

- All concrete components are kite marked to BS EN 1917 & BS 5911-3
- All joints have an elastomeric seal to BS EN 681-1
- The results of tests for water tightness and resistance to vertical loading shall satisfy the requirements of BS EN 1917
- Installation is undertaken by an approved installer in accordance with the CPSA Technical Guide No. 4 –October 2006

Concrete surround or anti flotation ring/s shall be provided where necessary. This approval is valid until it becomes non-compliant with Sewers for Adoption or any subsequent publication which replaces it.

Yours faithfully

John Hayes
Technical Standards Manager

