

28 August 2009

**Andy Cooper**

FP McCann Ltd  
Whitehill Road  
Ellistown  
Leicestershire  
LE67 1ET

**SCOTTISH WATER**

Castle House  
6 Castle Drive  
Carnegie Campus  
Dunfermline  
Fife KY11 8GG

Customer Helpline  
T: 0845 601 8855  
W: [www.scottishwater.co.uk](http://www.scottishwater.co.uk)  
E: [customer.service@scottishwater.co.uk](mailto:customer.service@scottishwater.co.uk)

Dear Sirs,

**McCann Easi Base – New Product Acceptance**

Having given due consideration to the use of FP McCann Easi-base pre-constructed bases, and being aware that they have been assessed against the appropriate standards by WRc, I can confirm that Scottish Water has no objections to their use or adoption.

Scottish Water therefore gives full acceptance for the installation of the following products:-

- Easi-Base Pre-cast Concrete Manhole Base with Polypropylene Lining – 1200mm diameter, WRc certificate - PT/274/0808 (valid 20/1/2008 to 20/1/2013)
- Easi-Base Pre-cast Manhole Bases with unlined – 1200mm, 1500mm, 1800mm and 2100mm diameter, WRc certificate - PT/279/0109 (valid 20/1/2009 to 20/1/2014)
- Easi-Base Pre-cast Manhole Bases with GRP lined – 1200mm, 1500mm, 1800mm and 2100mm diameter, WRc certificate PT/280/0109 (valid 20/1/2009 to 20/1/2014)

This acceptance is subject in all regards to conformity with the relevant edition of Sewers for Scotland applying at the time. This includes the supplementary performance and durability requirements of BS 5911 part 3. For clarity, we regard the current quality of benching in the product is equal or better to that in Sewers for Scotland and therefore deem it to conform.

Acceptance of the current products listed above by Scottish Water is valid with immediate effect for a period of 12 months or such time as it may become non-compliant with Sewers for Scotland or any subsequent publication or Regulation that replaces it.

Yours faithfully



Iain MacDonald  
Asset Management Technical Leader  
[iain.macdonald@scottishwater.co.uk](mailto:iain.macdonald@scottishwater.co.uk)